



- NOTES:
1. MATERIAL CARBON STEEL.
 2. SILENCER IS DESIGNED TO SUPPORT OWN WEIGHT ONLY.
 3. STANDARD MAXIM CONSTRUCTION TOLERANCE APPLY ($\pm 1/4"$).
 4. ALL WELDED CONSTRUCTION.
 5. DRAWING SUBJECT TO CHANGE WITHOUT NOTICE.

ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED. TOLERANCES APPLY ON CRITICAL DIMENSIONS AS SHOWN BELOW: $\pm 1/8"$ IMP FRAC; ± 0.125 IMP DEC ± 3.175 MM METRIC; $\pm 2^\circ$ ANGULAR	DRAWING TYPE: SALES			Maxim Silencers, Inc. 10639 Brighton Lane Stafford, TX 77477 PH (832) 554-0980 FX (832) 554-0990 www.Maximsilencers.com	
	DRAWN BY: TF	DATE: 08/04/09		TITLE: SILENCER HOSPITAL GRADE 26 M52 C SI	
DIM HOLD - CRITICAL DIMENSION	APPROVED BY:	DATE:	DRAWING NO.: M52-26C2		PROJECT/SALES ORDER NO. EXTERNAL FINISH: HT BLACK PAINT
THE INFORMATION HEREIN IS THE PROPERTY OF MAXIM SILENCERS INC. TRANSMITTAL TO OTHERS OR USE EXCEPT THAT FOR WHICH IT IS PROVIDED IS STRICTLY PROHIBITED. DO NOT SCALE DRAWING.		REF #: 1	EST. WEIGHT: 4566 LBS	SHIP DATE:	
THIRD ANGLE PROJECTION			SHEET: 1 OF 1		